

Declaration of Hygiene Conformity

Air handling units Type X-CUBE

Object of the inspection

TROX GmbH, Heinrich-Trox-Platz, D-47504 Neukirchen-Vluyn, Germany, hereby confirm that the air handling units of type X-CUBE meet the hygiene requirements specified by the standards and regulations listed below.

- European standard
– EN 13779 (09/2007)
- German standards
– VDI 6022, part 1 (07/2011)
– VDI 3803 (02/2010)
- Austrian standards
– ÖNORM H 6021 (09/2003)
- Swiss SWKI regulations
– VA104-01 (04/2006)


For the purpose of this declaration of conformity a sample of each type mentioned above was viewed at the TROX GmbH factory, Heinrich-Trox-Platz, 47504 Neukirchen-Vluyn, Germany, and related data sheets, technical literature, and inspection reports were appraised.

Summary of the test result

The examination of the above-mentioned sample equipment and the appraisal of the available documents have shown that the hygiene requirements specified by the above-mentioned standards and regulations are met.

We hereby confirm that the air handling units of type X-CUBE meet the hygiene requirements of the specified standards and regulations.

Neukirchen-Vluyn, Germany, 01 December 2011



B.Eng. Michael Schulze Greiving
trained according to VDI 6022, category A
Product Management



Dipl.-Ing. Jan Heymann

Manager Quality Systems

Certificate